

API STANDARD 607 SIXTH EDITION-2010 ISO 10497:2010 FIRE TEST CERTIFICATE



Name of Manufacturer:	KHIMJI FLOW EQUIPMENTS PVT. LTD., #67/E, 67/F, Tarihal- Revadihal Road, Hubli-580026, India	Test Date:	29-12-2014
Designation of Valve:	Ball valve FB series 'K'F3	Report/Certificate Number:	FS-17 Date: 29-12-2014
Size:	50mm (2 inch)	Pressure Rating:	Class 800
Body Material:	Carbon Steel ASTM A105	Seat Material:	PTFE
Trim Material:	Stainless Steel ASTM A 276 Type 304	Stem Seal/ Body Seal:	Grafoil

The above valve was tested in accordance with the above stated fire test procedure. All of the applicable test parameters were met and external and through leakage measurements were below the allowable limits. Other valves of the same construction may also be qualified according to the requirements of the test specification, Section 7.

This certificate refers to the above mentioned product. This is to certify that the test specimen provided is in conformity with the standard mentioned above.

Sizes Qualified:	2" and below; 2 ½,3" & 4"(RB & FB)	Pressure Ranges Qualified:	Class 800,900 & 1500
------------------	-------------------------------------	----------------------------	----------------------

Witnessed and Certified by:

Name:	TUV India, Technical Inspection Services
Address:	TUV India Pvt Ltd. Member of TUV Nord Group #8, PDS Tower, 1 st , 2 nd & 3 rd floor, 6 th block, Opp. Rajajinagar IT park, Rajajinagar, Bangalore-560010, India
Inspector:	Mr. Krishna Kalwad

Signature



Stamp